



**GRANULATED SINGLE SUPER PHOSPHATE PROJECT, FAGMIL CHITTORGARH**  
**Doc No: PC 107/E-1/P-II/5.4**  
**AMENDMENT-3\_Technical (Electrical), Date :26/03/2018**



SL. NO.	REFERENCE OF BIDDING DOCUMENT					MODIFICATION
	Part/Sec.	Page No.	Doc no	Clause No.	Subject	
1.	Part-II/ Section-5.4	8 of 47	PC 107/ E-1/ P-II/ 5.4	2.1.4	Redundancy	Clause no 2.1.4 of doc no PC 107/ E-1/ P-II/ 5.4 (page 8 of 47) stands deleted  Philosophy of one incomers without bus coupler shall be provided for switch boards except Emergency switchboards, feeding the emergency loads which shall have two power source namely normal and emergency.
2.	Part-II/ Section-5.4	14 of 47	PC 107/ E-1/ P-II/ 5.4	5.1.8, 5.1.11	Normal operation of 33KV, 3.3 KV Switchgears, Power-Cum-Motor Control Centre (PMCC) and Motor Control Centre (MCC)	33KV, 3.3KV Switchgears, Power-Cum-Motor Control Centre (PMCC) and Motor Control Centre (MCC) shall have only one incomer without bus coupler & Bus tie feeder except the switch boards feeding the emergency loads which shall have two power source namely normal and emergency.
3.	Part-II/ Section-5.4	26 of 47	PC 107/ E-1/ P-II/ 5.4	9.4.1.18	Auto change over	Clause no 9.4.1.8 shall be applicable only for the switch boards feeding the emergency loads which shall have two power source namely normal and emergency.
4.	Part-II/ Section-5.4	26 of 47	PC 107/ E-1/ P-II/ 5.4	9.4.1.24	Number of Transformer	All the HT/LT switchgear shall be fed through one transformer having capability to take care of 100% load of the associated switchgear with required spare margin as specified in NIT.
5.	Part-II/ Section-5.4	8 of 13	PC107/ E-006/P-II/5.4/TS-0803	5.9.3	Auto changeover	Deleted.