



GRANULATED SINGLE SUPER PHOSPHATE PROJECT, FAGMIL CHITTORGARH
Doc No: PC 107/E-1/P-II//3.0
AMENDMENT-1 (Process), Date :04/04/2018



SL. NO.	REFERENCE OF BIDDING DOCUMENT					MODIFICATION
	Part/Sec.	Page No.	Doc no	Clause No.	Subject	
1.	Part-II/ Section-3.0	16 of 35	PC107/E-001/P-II/3.0	2.11	Instrumentation	DCS/ESDS not required. General purpose PLC shall be provided. For details refer section Part-II/ Section-5.2 (Design Philosophy-Instrumentation) along with respective amendment.
2.	Part-II/ Section-3.0	-	PC107/E-001/P-II/3.0	New clause	Fire fighting provision	Design, supply, erection, testing, pre-commissioning & commissioning of the complete fire fighting & fire protection system of the total plant including all process areas, non-process areas, plant buildings, non-plant buildings and/or any other facility of the entire plant, as per code & local statutory requirements, shall be in the scope of and provided by LSTK contractor. For details refer section Part-II/ Section-5.3.5 (Design Philosophy-Fire Fighting system) along with respective amendment
3.	Part-II/ Section-3.0	18 of 35	PC107/E-001/P-II/3.0	2.12 (Electrical)	Redundancy	For details refer section Part-II/ Section-5.4 (Design Philosophy-Electrical) along with respective amendment.