



**GRANULATED SINGLE SUPER PHOSPHATE PROJECT, FAGMIL CHITTORGARH**  
**Doc No: PC 107/E-1/P-II//5.2**  
**AMENDMENT-5\_Technical (Instrumentation), Date :28/03/2018**



SL. NO.	REFERENCE OF BIDDING DOCUMENT					MODIFICATION
	Part/Sec.	Page No.	Doc no	Clause No.	Subject	
1.	Part-II/ Section-5.2		PC107/E-001/P-II/5.2	3.6	Hand held gas detector	No Hand held gas detector required. Clause no 3.6 stands deleted.
2.	Part-II/ Section-5.2		PC107/E-001/P-II/5.2	3.14	IP cameras	Not required. Clause no 3.14 stands deleted.
3.	Part-II/ Section-5.2		PC107/E-001/P-II/5.2	5.1	<b>Scope of Supply</b>	1) One (01 No) operator station required in place of 2 Nos. 2) Redundancy not required. Hence clause no (g) & (h) stands deleted.
4.	Part-II/ Section-5.2		PC107/E-001/P-II/5.2	10.0	<b>Gas detection system</b>	No gas detection system is required in the plant. Only Fire Alarm system to be considers.  If any stack monitoring requirement is there for gas, bidder to consider the same.