

BIDDER'S QUERIES FOR PRE BID MEETING

To,
M/s TALCHER FERTILIZERS LIMITED NOIDA
SUB: PRE BID QUERIES
TENDER NO: (NIT NO : PNMM/PC-183/E- 4026/NCB)

Sl. NO.	REFERENCE OF TENDER DOCUMENT				BIDDER'S QUERY	OWNER'S REPLY
	SEC. NO.	Page No.	Clause No	Subject		
1	TECHNICAL SPECIFICATION 220KV EHV POWER CABLE TFL, ODISHA GENERAL REQUIREMENTS:	Sheet 3 of 15	1	SCOPE: Conductor: 1000 sqmm Single core stranded <u>circular</u> compacted Copper Conductor	We would like to offer <u>4- segmented (Milliken)</u> type copper conductor instead of Circular Compacted for 1000 Sq.mm . We have Cable supply experience with 4- segmented (Milliken) conductor type to various utilities in india.	Please follow NIT only.
2	TECHNICAL SPECIFICATION 220KV EHV POWER CABLE TFL, ODISHA 5. ELECTRICAL TESTS ON THE CABLE AND ACCESSORIES:	Sheet 10 of 15	5	Type Tests: Tests carried out on same type and first pieces of cable and accessories of same voltage grade and same design.	As per IEC 62067 "Range of type approval", type test report of same or higher voltage grade cable having same or higher conductor cross section (Cu / Al) and the same or similar construction (similar type and similar manufacturing process of insulation and semiconducting screen) are valid & acceptable meeting the condition of conductor stress & insulation stress. Kindly confirm your acceptance for the type test report as per IEC 62067 Range of type approval.	Please follow NIT only.
3	TECHNICAL SPECIFICATION 220KV EHV POWER CABLE TFL, ODISHA 5. ELECTRICAL TESTS ON THE CABLE AND ACCESSORIES: TYPE TESTS & ACCEPTANCE TESTS:	Sheet 10 of 15	5	Following Acceptance tests shall be conducted as per IS 7098-3/IEC 62067/IEC60811 5. Void and contaminants test 11. Tan delta measurement as a function of temperature and voltage 12. A.C. test on insulation.	As per Indian & International standard (IS 7098-3/IEC 62067/IEC60811) Void and contaminants test, Tan delta measurement as a function of temperature and voltage, A.C. test on insulation are not applicable under Acceptance tests. Please amend the clause.	All acceptance tests shall be done as per relevant latest IS/IEC.
4	Section 2	13	1.A.1.III	Bidder shall have valid type test certificates of 220KV cable as per latest relevant IS of not more than 10 years. The type tests reports shall be valid as on the last date of submission of bid for 220KV cables.	Please confirm, whether Bidders can also submit the Type Tests of 220 kV and above voltages as per IEC standards in response to this Pre Qualification criteria	As per NIT only.

NOTE: The Pre-Bid Queries may be sent by e-mail before due date for receipt of Bidder's queries.

BIDDER'S QUERIES FOR PRE BID MEETING

SUB: Clarification against supply of **220KV D/C SINGLE CORE 1000Sq. MM COPPER XLPE CABLE AT TALCHER FERTILIZERS LTD., ANGUL, ODISHA."**

TENDER NO:PNMM/PC-183/E-4026/NCB Dated: 13.09.2024

Sl. NO					BIDDER'S	OWNER'S
	SEC. NO.	Page No.	Clause No	Subject	QUERY	REPLY
1	SECTION-II	17	(F) Authentication of documents submitted against BEC	Bidder shall necessarily be duly certified/ attested by Chartered Engineer as well as Notary Public with legible stamp.	Kindly waive off the basic evaluation documents attested by a chartered engineer. Only attestation by a Notary Public is applicable.	No change in NIT terms & conditions. Bidder is advised to quote as per NIT.
2	[A] – GENERAL	39	EARNEST MONEY DEPOSIT	Bank Guarantee' strictly as per the format given in form F-2A	Kindly arrange and provide the Complete beneficiary address , because as per bank it is mandatory	Please refer page 79, BIDDING DATA SHEET (BDS) Annexure IV of Instruction to bidders.
3	[A] – GENERAL	39	EARNEST MONEY DEPOSIT	Bank Guarantee' strictly as per the format given in form F-2A	As per mentioned clause, last EMD validity date is your claim date, kindly clarify	EMD should have a validity of at least "two [02] months" beyond the validity of the Bid.
4	SECTION-VI	234	DESIGN DATA: TECHNICALPARTICULARS	Length of Drum	Kindly increase individual and over all drum tolerance 2 % instead of 1%.	No change in NIT terms & conditions